


OFFICE OF THE SUB DIVISIONAL ENGINEER WATER SUPPLY &
SANITATION SUB DIVISION NO. 4, SRI MUKTSAR SAHIB
EMAIL ID- mktsde4@gmail.com Sri Muktsar Sahib

Dispatch No. 485

Dated. 26-04-2024

WATER SUPPLY & SANITATION CERTIFICATE

It is certified that Water Supply & Sanitation of DESH BHAGAT
GLOBAL SCHOOL , SRI MUKTSAR SAHIB is Good. Drinking Water is Potable as
tested.


Sub Divisional Engineer,
W/S & Sanitation Sub Div No. 4,
Sri Muktsar Sahib.

TEST REPORT

Name & Address of Customer :
**desh bhagat global school
 muktsar**

Customer Reference No. No : 110 Dated : 02/04/2024
 Sample Submitted by baghi
 Date of Sample Receipt 22/04/2024
 Analysis Starting Date 22/04/2024
 Analysis completion Date 23/04/2024

Discipline : **Chemical Testing**

ULR No.:
 Test Report No.: **DWTL/MKS/2425/00027**
 Registration no.: **DWTL/MKS/REG2425/00027**
 Collection Point: **Treatment Plant (RO/CWPP/ARP/HH Purifier)**
 Scheme/Source: **Not Mentioned(Not Mentioned)**
 Village : **Not Mentioned**
 Block: **Not Mentioned**
 Latitude : **Not Mentioned**

Group: **Water**
 Sample Type : **Treated Water**
 Date of Issue : **24/04/2024**
 Condition of Sample : **Sealed**
 Quantity/Type of Bottle: **1000 ml / Amber Colored Glass Bottle**
 Location/Depth : **muktsar / NA**
 Habitation : **Not Mentioned**
 District : **Muktsar**
 Longitude: **Not Mentioned**

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
	pH	6.92	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
	Odour	agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
	Taste	agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
	TDS	80	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
	Turbidity	0.6	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
	Alkalinity(CaCO3)	52	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
	Hardness(CaCO3)	56	200	600	mg/l	IS 3025 (Part 21-2009)(RA 2019) EDTA Method
	Calcium(Ca)	16	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
	Magnesium(Mg)	4	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B. Calculation Method
	Chloride(Cl)	20	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

- The results apply to the sample as received only.
- The sample will be destroyed after retention time unless otherwise specified specially.
- This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
- Abbreviation used (TDS - Total Dissolved Solids, mg/l - milligram per liter, BDL - Below detection limit, APHA - American Public Health Association, IS - Indian Standard, NT - Not Tested, NA - Not Applicable NTU - Nephelometric Turbidity Unit, RA - Reaffirmed, ND - Not Detected)
- * Value not available or test not performed for this parameter.
- Temperature condition limit: 25±5°C and Humidity condition limit: 50 ±20%

Reviewed and Approved By

Ashish Kumar

Ashish Kumar
 Sr. Chemist
 Authorized Signatory
 For, District Water Testing Laboratory
 Sh. Muktsar Sahib

DISTRICT WATER TESTING LABORATORY, SH. MUKTSAR SAHIB

Water supply and Sanitation Department, Division no 1, kotkapoora road near vishal mega Mart, Distt Muktsar, Pin code 152026
dwtlmks@gmail.com

Bill No. : INV/2425/00027

INVOICE

Date. : 22/04/2024

To,
desh bhagat global school
mukatsar

Ref. : Letter No. 110 Dt. 02/04/2024

Sample Receiving No. DWTL/MKS/R2425/00027 Dt. 22/04/2024

No.	Name of Scheme / Source / Location	Nature of Sample	Category Name	Test Parameter	No. of Sample	Rate Per Parameter/ Set of Parameters	Net Amount
1	muktsar	Treated Water	Private Schools	Basic Chemical : pH, Colour, Odour, Taste, TDS, Turbidity, Alkalinity, Hardness, Calcium, Magnesium, Chloride	1	130.00	130.00
Total							130.00

Payment Mode : Cash

Payment Status : PAID

One Hundred Thirty

Note: * Discount applicable as per Government Notification Number : No 9284 & Date : 09/11/2021

STR No. : NA

Authorised Signatory